

THE ADMINISTRATION OF UNION TERRITORY OF LADAKH
OFFICE OF THE DIRECTOR FIRE AND EMERGENCY SERVICES UT LADAKH
(e-mail: igp-ladakh@police.ladakh.gov.in)

(Office Phone No.01982-260888)

No: - PHQ/Dir/F&ES/UTL/2021- 43-44
Dated: 04 /1/2022

Subject: Fire NOC in favour of Govt. Higher Secondary School Yourbaltak, Kargil.

The report has been submitted by Superintendent of Police, Fire and Emergency Services, Ladakh regarding the inspection of the instant school which has been done by I/C Fire and Emergency Services, Kargil. The detailed report is as under:

Location/ Accessibility:

The School is constructed at Yourbaltak, Kargil. It is located at latitude 34.565708 and longitude 76.197481. The site is approximately 20 Kms away from Fire and Emergency Services Station, Kargil. It takes approximately 30 minutes to reach the site which is not approachable for fire appliances.

Detail of building:

The school building have three blocks and the detail of the block are as under:

1st block: It is three stored school building having one stair case. In the ground floor there are two class rooms, two ICT labs, principle office, staff room and account office. There are two windows in each room and the size of windows 6x4 feet and 4x5 feet. All the windows have provision to open. 1st Floor has 04 class rooms and 2nd floor have library room and computer room.

2nd block: It is two storied building having one stair case. In the ground floor there are four laboratory rooms each room have two windows. The size of the windows is 6x5 feet. All the windows have provision to open. 1st floor have examination hall and the size of the hall is 60x27 feet.

3rd block: It is single stored wooden structure building having two store room, one kitchen room and one multipurpose hall and the size of the hall is 65x16 feet. All the room have one window and hall have five windows. The size of the window is 4x2'6" feet. All the windows have provision to open.

The following Fire Safety equipment's found installed in School Building:

01. 04 no's of fire extinguishers ABC Type 6kg and 03 4kg installed in the school building.
02. 02 no of sand buckets appropriately placed in the school premises.
03. 03 no of plastic water tanks 500 litres capacity at overhead and 2000 liters of iron water tanks along with three no. of 300 liters plastic tanks places in the building.
04. One submersible bore connected with high rated pump.

There is a mandatory requirement for keeping 2 exit stair cases in each block of the school building each having at least 1.5 meter width besides constructing 20 thousand litres of underground water tank in school premises along with placement of 8 number of fire extinguishers 6 kg capacity and 8 no of sand buckets in the school.

A provisional FIRE NOC for a period of 6 months is given to **Govt. Higher Secondary School Yourbaltak, Kargil** from the date of issuance of this letter and the

school management is advised to fulfilling the above listed fire safety requirements in shortest possible time.



**Director, F&ES, Ladakh
PHQ, Agaling, Leh**

Copy to:

1. Principal, Govt. Higher Secondary School Yourbaltak, Kargil for info
2. Superintendent of Police, F&ES, Ladakh for information and n/a